

APPENDIX I

SCHEME DATA SHEETS

Scheme Data Sheets

Scheme Reference Number	Title of Scheme
WW01	Saida
WW02	Sarafund
WW03	Sour
WW04	Naqoura
WW05	Jbaa
WW06	Nabatiyeh
WW07	Nabaa El-Tasseh
WW08	Chaqra
WW09	Tibnine
WW10	Bint Jbeil
WW11	Marjayoun
WW12	Jezzine
WW13	Braiqaa-Maifadoun
WW14	Kfar Sir
WW15	Hallousieh
WW16	Srifa
WW17	Wadi Slouqi
WW18	Yohmor
WW19	Zaoutar
WW20	Deir Mimes
WW21	El Aachiyeh
WW22	Kafra
WW23	Rihane
WW24	Mimes
WW25	Hasbaya
WW26	Hebbariyeh
WW27	Kaoukaba
WW28	Rachaya El Foukhar
WW29	Kfarshouba
WW30	El Meri
WW31	El Wazzani
WW32	Chebaa

GENERAL NOTE

- ❖ All in-locality collection networks proposed in the South Lebanon Wastewater Master Plan will have approximately 80% of the pipelines of 200 mm diameter and 20% of the pipelines of 300 mm diameter.
- ❖ At later advanced stages of studies (Feasibility Studies, Environmental Impact Assessment, and Detailed Design), wastewater characterization must be carried out for all schemes whether they have been previously studied by previous Consultant or newly proposed in the Master Plan by RELK&P.
- ❖ It should be noted that at this stage of study, several schemes have no proposed pumping/lift stations as the alternative of gravity-driven wastewater flow was adopted in the process of development of the Master Plan. However, pumping/lift stations might be proposed in the Detailed Design stage (where deemed necessary).
- ❖ It should be noted that the schemes which were studied by previous Consultants were revised by RELK&P and wherever necessary additional remarks were made by RELK&P as seen below.
- ❖ It should be noted that the populations applied for these 32 schemes are those that are determined by the Central Administration for Statistics (CAS) which are based on the total number of households per Muhafaza. These figures are projected to obtain population equivalent figures for the year 2030.

SAIDA SCHEME

WW01	South Lebanon Wastewater Master Plan – Saida Scheme																																																																		
Number of localities served	90																																																																		
Localities served	Saida, Ain El Heloue, Ghaziye, Hara, Hlaliye, Miye ou Miye, Bqosta, Aabra, Aanqoun, Aaqtanit, Ain Ed Delb, Ain El Mir, Bayssour, El Bramiye, Choualiq, Darb Es Sim, Jinsnaya, Kefraya, Kfarfalous, Kfar Jarra, Lebaa, Maamariye, Maghdouche, Majdelyoun, Ouadi Baanqoudain, Qennarit, Qraiye, Salhiye, Karkha, Tambourit, Houmine et Tahta, Zahrani, Mrah el Hbas, Jernaya, Kfar Chellal, Kfar Beit, Berti, Haitoule, Ouadi El Laimoun, Hassaniye, Mharbiye, Kfarhatta, Mjeidel, Zaghdraya, Arab Ej Jall, Arab Tabbaya, Bnaafoul, Mazraat Zeita, Mazraat Jinjlaya, Mazraat el Qnaitra, Roumine, Aazze, ErKay, Khzaiz, Roum, Aazour, Anane, Qaitoule, Homsiyeh, Haidab, Saidoun, Rimat, Sanaya, Mrah Bou Chdid, Maknouniye,																																																																		
Previously studied by	RELK&P – 1996 (Coastal Area Detailed Design) RELK&P – 2004 (Preliminary design for extension)																																																																		
Design population	2005 Population: 251,943 2030 Population Equivalent: 554,237																																																																		
Daily Average Flow	1,025 l/s																																																																		
Peak flow	1,958 l/s																																																																		
Network																																																																			
Main Collectors	<p>In the Saida scheme, there are existing pipelines as detailed below. There is also a proposal by RELK&P to extend the Saida scheme to include additional localities.</p> <p>Existing:</p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr><td>Pipelines</td><td>7.44</td><td>200</td></tr> <tr><td>Pipelines</td><td>15.95</td><td>300</td></tr> <tr><td>Pipelines</td><td>0.67</td><td>400</td></tr> <tr><td>Pipelines</td><td>1.12</td><td>500</td></tr> <tr><td>Pipelines</td><td>1.18</td><td>600</td></tr> <tr><td>Pipelines</td><td>1.96</td><td>700</td></tr> <tr><td>Pipelines</td><td>0.78</td><td>800</td></tr> <tr><td>Pipelines</td><td>1.87</td><td>1000</td></tr> <tr><td>Pipelines</td><td>67.91</td><td>Old Existing System</td></tr> <tr><td>Total Length</td><td>98.92</td><td></td></tr> </tbody> </table> <p>Partially Implemented (to complete execution later):</p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr><td>Pipelines</td><td>44</td><td>300 mm</td></tr> <tr><td>Total Length</td><td>44</td><td></td></tr> </tbody> </table> <p>Proposed:</p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr><td>Pipelines</td><td>35.47</td><td>200</td></tr> <tr><td>Pipelines</td><td>96.23</td><td>300</td></tr> <tr><td>Pipelines</td><td>9.89</td><td>400</td></tr> <tr><td>Pipelines</td><td>12.15</td><td>500</td></tr> <tr><td>Pipelines</td><td>5.04</td><td>600</td></tr> <tr><td>Pipelines</td><td>2.77</td><td>700</td></tr> <tr><td>Total Length</td><td>161.57</td><td></td></tr> </tbody> </table>	Collectors	Length (km)	Diameter (mm)	Pipelines	7.44	200	Pipelines	15.95	300	Pipelines	0.67	400	Pipelines	1.12	500	Pipelines	1.18	600	Pipelines	1.96	700	Pipelines	0.78	800	Pipelines	1.87	1000	Pipelines	67.91	Old Existing System	Total Length	98.92		Collectors	Length (km)	Diameter (mm)	Pipelines	44	300 mm	Total Length	44		Collectors	Length (km)	Diameter (mm)	Pipelines	35.47	200	Pipelines	96.23	300	Pipelines	9.89	400	Pipelines	12.15	500	Pipelines	5.04	600	Pipelines	2.77	700	Total Length	161.57	
Collectors	Length (km)	Diameter (mm)																																																																	
Pipelines	7.44	200																																																																	
Pipelines	15.95	300																																																																	
Pipelines	0.67	400																																																																	
Pipelines	1.12	500																																																																	
Pipelines	1.18	600																																																																	
Pipelines	1.96	700																																																																	
Pipelines	0.78	800																																																																	
Pipelines	1.87	1000																																																																	
Pipelines	67.91	Old Existing System																																																																	
Total Length	98.92																																																																		
Collectors	Length (km)	Diameter (mm)																																																																	
Pipelines	44	300 mm																																																																	
Total Length	44																																																																		
Collectors	Length (km)	Diameter (mm)																																																																	
Pipelines	35.47	200																																																																	
Pipelines	96.23	300																																																																	
Pipelines	9.89	400																																																																	
Pipelines	12.15	500																																																																	
Pipelines	5.04	600																																																																	
Pipelines	2.77	700																																																																	
Total Length	161.57																																																																		
In-Locality Collection Network	736 km																																																																		

Pumping/Lift Station (s)	<table border="1"> <thead> <tr> <th>Item</th> <th>Description</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Pumping/lift stations**</td> <td>10</td> </tr> </tbody> </table>		Item	Description	Quantity	1	Pumping/lift stations**	10
	Item	Description	Quantity					
1	Pumping/lift stations**	10						
<p>** 10 pumping/lifting stations are operational in the Saida scheme; they are located at the coastal area</p>								
Treatment								
Design Capacity	88,560 m3/day							
WW Characterization	Wastewater characterization was not carried out by the previous Consultant (refer to general notes).							
Proposed WW treatment process	Existing: a Primary Treatment plant at present, completed but not commissioned yet Proposed: upgrade to secondary treatment; Aerobic Treatment, Extended Aeration Activated Sludge							
Proposed location of WWTP	Existing – on the right bank of the Sainiq River and it is operational							
Additional Remarks	There are two treatment plants by USAID existing in Berti and Snayyah and they are both operational.							

SARAFUND SCHEME

WW02	South Lebanon Wastewater Master Plan – Sarafund Scheme																																																															
Number of localities served	62																																																															
Localities served	<p>Sub-scheme 1: Khartoun, Ghassaniyeh, M Kaouthariyet Essiyad, Ech Charqiyeh, Mazraat Sinai, Insar, Mazraat El Qraiye, Mazraat Deir Mar Taqla, Ez Zrariye, Mazraat Kaouthariyet erriz, Mazraat Jamjim, Arzai, Matariyet Ech Choumar, El Kharayeb, Mazraat El Ousta</p> <p>Sub-scheme 2: Deir Ez Zahrani, Kfaroua, En Nmairiye, El Hajje, Zefta, En Najjariye, Mseileh, Maamriyet El Kharab, El Addoussiye, El Marouaniye, Tefahta, Bissariye, Yarine, Mazraat El Aaqbiye, Babliye, Khirbet Ed Douair, Qaaqaiyet Es Snoubar, Sarafund, Saksakiye, Loubiye, Insariye, Aadloun</p>																																																															
Previously studied by	GETI – 2005 (Feasibility Study)																																																															
Design population	<p><i>Sub-scheme 1:</i> 2005 Population: 44,549 2030 Population Equivalent: 102,631</p> <p><i>Sub-scheme 2:</i> 2005 Population: 84,629 2030 Population Equivalent: 183,154</p>																																																															
Daily Average Flow	560 l/s																																																															
Peak flow	1,342 l/s																																																															
Network																																																																
Main Collectors	<p><i>Sub-scheme 1:</i></p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr><td>Pipelines</td><td>76.05</td><td>200</td></tr> <tr><td>Pipelines</td><td>21.10</td><td>250</td></tr> <tr><td>Pipelines</td><td>2.82</td><td>300</td></tr> <tr><td>Pipelines</td><td>7.69</td><td>350</td></tr> <tr><td>Pipelines</td><td>5.42</td><td>400</td></tr> <tr><td>Pipelines</td><td>5.04</td><td>500</td></tr> <tr><td>Pipelines</td><td>0.99</td><td>700</td></tr> <tr><td>Total Length</td><td>119.11</td><td></td></tr> </tbody> </table> <p><i>Sub-scheme 2:</i></p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr><td>Pipelines</td><td>120.09</td><td>200</td></tr> <tr><td>Pipelines</td><td>7.24</td><td>250</td></tr> <tr><td>Pipelines</td><td>16.96</td><td>300</td></tr> <tr><td>Pipelines</td><td>4.84</td><td>350</td></tr> <tr><td>Pipelines</td><td>5.17</td><td>400</td></tr> <tr><td>Pipelines</td><td>11.51</td><td>450</td></tr> <tr><td>Pipelines</td><td>1.55</td><td>500</td></tr> <tr><td>Pipelines</td><td>1.74</td><td>700</td></tr> <tr><td>Pipelines</td><td>1.32</td><td>800</td></tr> <tr><td>Pipelines</td><td>0.32</td><td>900</td></tr> <tr><td>Total Length</td><td>170.74</td><td></td></tr> </tbody> </table>	Collectors	Length (km)	Diameter (mm)	Pipelines	76.05	200	Pipelines	21.10	250	Pipelines	2.82	300	Pipelines	7.69	350	Pipelines	5.42	400	Pipelines	5.04	500	Pipelines	0.99	700	Total Length	119.11		Collectors	Length (km)	Diameter (mm)	Pipelines	120.09	200	Pipelines	7.24	250	Pipelines	16.96	300	Pipelines	4.84	350	Pipelines	5.17	400	Pipelines	11.51	450	Pipelines	1.55	500	Pipelines	1.74	700	Pipelines	1.32	800	Pipelines	0.32	900	Total Length	170.74	
Collectors	Length (km)	Diameter (mm)																																																														
Pipelines	76.05	200																																																														
Pipelines	21.10	250																																																														
Pipelines	2.82	300																																																														
Pipelines	7.69	350																																																														
Pipelines	5.42	400																																																														
Pipelines	5.04	500																																																														
Pipelines	0.99	700																																																														
Total Length	119.11																																																															
Collectors	Length (km)	Diameter (mm)																																																														
Pipelines	120.09	200																																																														
Pipelines	7.24	250																																																														
Pipelines	16.96	300																																																														
Pipelines	4.84	350																																																														
Pipelines	5.17	400																																																														
Pipelines	11.51	450																																																														
Pipelines	1.55	500																																																														
Pipelines	1.74	700																																																														
Pipelines	1.32	800																																																														
Pipelines	0.32	900																																																														
Total Length	170.74																																																															

In-Locality Collection Network	<p><i>Sub-scheme 1:</i> 169 Km</p> <p><i>Sub-scheme 2:</i> 301 Km</p>																																		
Pumping/Lift Station (s)	<table border="1"> <thead> <tr> <th>Item</th> <th>Description</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Pumping and lifting stations</td> <td>4</td> </tr> <tr> <td>2</td> <td>Pumping and lifting stations associated with the two (2) treatment plants</td> <td>2</td> </tr> </tbody> </table>	Item	Description	Quantity	1	Pumping and lifting stations	4	2	Pumping and lifting stations associated with the two (2) treatment plants	2																									
Item	Description	Quantity																																	
1	Pumping and lifting stations	4																																	
2	Pumping and lifting stations associated with the two (2) treatment plants	2																																	
Treatment																																			
Design Capacity	48,384 m ³ /day																																		
WW Characterization	<p>Sampling was conducted between 15 Nov 2004 and 15 Jun 2005 on two untreated WW streams discharging at El Aaqbiye and En Nmairiye. Seventeen untreated WW grab samples were collected and analyzed. The tested WW was found to be predominately domestic with medium to high strength.</p> <table border="1"> <thead> <tr> <th rowspan="2">Parameter</th> <th colspan="3">El Aaqbiye</th> <th colspan="3">En Nmairiye</th> </tr> <tr> <th>Ave</th> <th>Min</th> <th>Max</th> <th>Ave</th> <th>Min</th> <th>Max</th> </tr> </thead> <tbody> <tr> <td>BOD₅ (mg/l)</td> <td>238.0</td> <td>120.0</td> <td>350.0</td> <td>213.2</td> <td>81</td> <td>327</td> </tr> <tr> <td>TSS (mg/l)</td> <td>152.4</td> <td>76.0</td> <td>247.0</td> <td>150.2</td> <td>70</td> <td>246</td> </tr> <tr> <td>F Coliform (No./100ml)</td> <td>57,553</td> <td>1,400</td> <td>93,000</td> <td>48,765</td> <td>5,000</td> <td>99,000</td> </tr> </tbody> </table> <p>The Consultant proposed to adopt the following influent WW characteristics: BOD₅ 360 mg/l TSS 360 mg/l Fecal Coliform 6 x 10⁶/100 ml</p>	Parameter	El Aaqbiye			En Nmairiye			Ave	Min	Max	Ave	Min	Max	BOD₅ (mg/l)	238.0	120.0	350.0	213.2	81	327	TSS (mg/l)	152.4	76.0	247.0	150.2	70	246	F Coliform (No./100ml)	57,553	1,400	93,000	48,765	5,000	99,000
Parameter	El Aaqbiye			En Nmairiye																															
	Ave	Min	Max	Ave	Min	Max																													
BOD₅ (mg/l)	238.0	120.0	350.0	213.2	81	327																													
TSS (mg/l)	152.4	76.0	247.0	150.2	70	246																													
F Coliform (No./100ml)	57,553	1,400	93,000	48,765	5,000	99,000																													
Proposed WW treatment process	<p>- First phase: preliminary treatment with sea outfall (2.90 km). - Second phase: the treatment process should be extended to include activated sludge with primary sedimentation. Sludge treatment: gravity sludge thickeners, anaerobic sludge digestion, and centrifugation for sludge dewatering. The WWTP will follow the Extended Aeration Activated Sludge method with possible reuse of the treated effluent in irrigation.</p>																																		
Proposed location of WWTP	<p>The first treatment plant will be located just south of the Zahrani Refinery in Mazraat Brak et Tall. The second treatment plant will be located in the Abou El Aswad coastal plain area. The centralized WWTP will be located south of the Zahrani Refinery in Mazraat Brak et Tall. The total area required for these plants is approximately 53,000m².</p>																																		
Additional Remarks	-																																		

SOUR SCHEME

WW03	South Lebanon Wastewater Master Plan – Sour Scheme																																																																					
Number of localities served	58																																																																					
Localities served	Aabbassiye, Aaitit, Aain Baal, Arzoun, Bedyas, Bafliye, Barich, Batoulay, Bestiyat, Borj Ech Chemali, Borj Rahal, Charbriha, Chehour, Deir Qanoun (Smaiye), Deir Qanoun En Nahr, Derdghaiya, El Bazouriye, El Bourghliye, El Haouch, Er Rachidiye, Es Smaiye, Hanaouy, Jennata, Kneisse, Maachouq, Maarake, Maaroub, Qana, Ras El Aain, Rechknaney, Rmadiye, Saddiqine, Sour El Bass, Tair Debbe, Toura, Yanouth, Kfardounine, Chehabiye, El Mjadel, Jonaya, Debaal, Deir Ntar, Mahrouna, Silaa, Mazraat Michrif, Deir Aamas, El Bayad, Ouadi Jilo																																																																					
Previously studied by	Laymeyer - 1994 Khalil Barakat – year NA RELK&P – 1996																																																																					
Design population	2005 Population: 238,890 2030 Population Equivalent: 517,843																																																																					
Daily Average Flow	973.54 l/s																																																																					
Peak flow	1,888.68 l/s																																																																					
Network																																																																						
Main Collectors	<p>* In Sour there are existing pipelines as detailed below. There is also a proposal to extend the Sour scheme to include additional localities.</p> <p>Existing:</p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>22.41</td> <td>Old Existing System</td> </tr> <tr> <td>Pipelines</td> <td>6.49</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>2.08</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>1.18</td> <td>400</td> </tr> <tr> <td>Pipelines</td> <td>4.72</td> <td>600</td> </tr> <tr> <td>Pipelines</td> <td>3.64</td> <td>700</td> </tr> <tr> <td>Pipelines</td> <td>5.28</td> <td>800</td> </tr> <tr> <td>Pipelines</td> <td>0.90</td> <td>900</td> </tr> <tr> <td>Pipelines</td> <td>0.93</td> <td>1000</td> </tr> <tr> <td>Pipelines</td> <td>1.25</td> <td>1200</td> </tr> <tr> <td>Total Length</td> <td>48.90</td> <td></td> </tr> </tbody> </table> <p>Proposed:</p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>90.67</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>3.63</td> <td>250</td> </tr> <tr> <td>Pipelines</td> <td>43.55</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>20.76</td> <td>400</td> </tr> <tr> <td>Pipelines</td> <td>22.11</td> <td>500</td> </tr> <tr> <td>Pipelines</td> <td>5.09</td> <td>600</td> </tr> <tr> <td>Pipelines</td> <td>11.81</td> <td>700</td> </tr> <tr> <td>Pipelines</td> <td>0.84</td> <td>800</td> </tr> <tr> <td>Pipelines</td> <td>1.27</td> <td>1200</td> </tr> <tr> <td>Total Length</td> <td>199.73</td> <td></td> </tr> </tbody> </table>	Collectors	Length (km)	Diameter (mm)	Pipelines	22.41	Old Existing System	Pipelines	6.49	200	Pipelines	2.08	300	Pipelines	1.18	400	Pipelines	4.72	600	Pipelines	3.64	700	Pipelines	5.28	800	Pipelines	0.90	900	Pipelines	0.93	1000	Pipelines	1.25	1200	Total Length	48.90		Collectors	Length (km)	Diameter (mm)	Pipelines	90.67	200	Pipelines	3.63	250	Pipelines	43.55	300	Pipelines	20.76	400	Pipelines	22.11	500	Pipelines	5.09	600	Pipelines	11.81	700	Pipelines	0.84	800	Pipelines	1.27	1200	Total Length	199.73	
Collectors	Length (km)	Diameter (mm)																																																																				
Pipelines	22.41	Old Existing System																																																																				
Pipelines	6.49	200																																																																				
Pipelines	2.08	300																																																																				
Pipelines	1.18	400																																																																				
Pipelines	4.72	600																																																																				
Pipelines	3.64	700																																																																				
Pipelines	5.28	800																																																																				
Pipelines	0.90	900																																																																				
Pipelines	0.93	1000																																																																				
Pipelines	1.25	1200																																																																				
Total Length	48.90																																																																					
Collectors	Length (km)	Diameter (mm)																																																																				
Pipelines	90.67	200																																																																				
Pipelines	3.63	250																																																																				
Pipelines	43.55	300																																																																				
Pipelines	20.76	400																																																																				
Pipelines	22.11	500																																																																				
Pipelines	5.09	600																																																																				
Pipelines	11.81	700																																																																				
Pipelines	0.84	800																																																																				
Pipelines	1.27	1200																																																																				
Total Length	199.73																																																																					
In-Locality Collection Network	630 Km																																																																					

Pumping/Lift Station (s)	<table border="1"> <thead> <tr> <th>Items</th> <th>Description</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Pumping/Lift Stations*</td> <td>8</td> </tr> </tbody> </table>			Items	Description	Quantity	1	Pumping/Lift Stations*	8
	Items	Description	Quantity						
1	Pumping/Lift Stations*	8							
*There exist 8 pumping / lift stations that are operational in the area of Sour.									
Treatment									
Design capacity	84,154 m3/day								
WW Characterization	Wastewater characterization was not carried out by the previous Consultant (refer to general notes).								
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge								
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout								
Additional Remarks									

NAQOURA SCHEME

WW04	South Lebanon Wastewater Master Plan – Naqoura Scheme
Previously studied by	Ecofluid – 2004 (not adopted)

The Scheme of Naqoura is subdivided into four sub-schemes; for each scheme the total lengths of the wastewater network and the treatment features are defined separately as indicated in the sections below.

Sub-scheme 1	South Lebanon Wastewater Master Plan – Naqoura Scheme Sub-scheme 1 of 4												
Number of localities served	7												
Localities served	Zheiriye, El Malkiye, El Biyada, Majdel Zoun, Chamaa, El Henniye, Aaziye, El Mansouri, El Qleile												
Design population	2005 Population: 16,941 2030 Population Equivalent: 36,351												
Daily Average Flow	59.25 l/s												
Peak flow	178.94 l/s												
Network													
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>14.21</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>6.67</td> <td>400</td> </tr> <tr> <td>Total Length</td> <td>20.88</td> <td></td> </tr> </tbody> </table>	Collectors	Length (km)	Diameter (mm)	Pipelines	14.21	300	Pipelines	6.67	400	Total Length	20.88	
Collectors	Length (km)	Diameter (mm)											
Pipelines	14.21	300											
Pipelines	6.67	400											
Total Length	20.88												
In-Locality Collection Network	<i>Sub-scheme 1:</i> 66 Km												
Pumping/Lift Station (s)	No pumping stations have been proposed by RELK&P at this stage of study.												
Treatment													
Design capacity	5,119m ³ /day												
WW characterization	Wastewater characterization was not carried out at this stage of study. (refer to general notes).												
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge												
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout												
Additional Remarks													

NAQOURA SCHEME
Sub-scheme 2

Sub-scheme 2	South Lebanon Wastewater Master Plan – Naqoura Scheme Sub-scheme 2 of 4														
Number of localities served	11														
Localities served	Chihine, Marouahine, Oun Toute, Zalloutiye, Boustane, Jijim, Tair Harfa, Matmoura, Dhaira, Yarine, Jebbain														
Design population	2005 Population: 4,847 2030 Population Equivalent: 9,943														
Daily Average Flow	16.21 l/s														
Peak flow	60.78 l/s														
Network															
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>15.89</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>1.24</td> <td>400</td> </tr> <tr> <td>Total Length</td> <td>17.13</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	15.89	300	Pipelines	1.24	400	Total Length	17.13	
Collectors	Length (km)	Diameter (mm)													
Pipelines	15.89	300													
Pipelines	1.24	400													
Total Length	17.13														
In-Locality Collection Network	<i>Sub-scheme 2:</i> 24.23km														
Pumping/Lift Station (s)	No pumping stations have been proposed by RELK&P at this stage of study.														
Treatment															
Design capacity	1,400m ³ /day														
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).														
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge														
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout														
Additional Remarks															

NAQOURA SCHEME
Sub-scheme 3

Sub-scheme 3	South Lebanon Wastewater Master Plan – Naqoura Scheme Sub-scheme 3 of 4											
Number of localities served	3											
Localities served	El Borj, Naqoura, Aalma ech Chaab											
Design population	2005 Population: 3,882 2030 Population Equivalent: 8,258											
Daily Average Flow	13.46 l/s											
Peak flow	51.96 l/s											
Network												
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>6.99</td> <td>300</td> </tr> <tr> <td>Total Length</td> <td>6.99</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	6.99	300	Total Length	6.99	
Collectors	Length (km)	Diameter (mm)										
Pipelines	6.99	300										
Total Length	6.99											
In-Locality Collection Network	<i>Sub-scheme 3:</i> 17.35 km											
Pumping/Lift Station (s)	No pumping stations have been proposed by RELK&P at this stage of study.											
Treatment												
Design capacity	1,163m ³ /day											
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks												

NAQOURA SCHEME
Sub-scheme 4

Sub-scheme 4	South Lebanon Wastewater Master Plan – Naqoura Scheme Sub-scheme 4 of 4											
Number of localities served	2											
Localities served	Jbal el Botm, Zabqine											
Design population	2005 Population: 2,398 2030 Population Equivalent: 5,103											
Daily Average Flow	8.32 l/s											
Peak flow	34.85 l/s											
Network												
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>4.98</td> <td>300</td> </tr> <tr> <td>Total Length</td> <td>4.98</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	4.98	300	Total Length	4.98	
Collectors	Length (km)	Diameter (mm)										
Pipelines	4.98	300										
Total Length	4.98											
In-Locality Collection Network	<i>Sub-scheme 4:</i> 12 km											
Pumping/Lift Station (s)	No pumping stations have been proposed by RELK&P at this stage of study.											
Treatment												
Design capacity	719 m3/day											
WW characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks												

JBAA SCHEME

WW05	South Lebanon Wastewater Master Plan – Jbaa Scheme																				
Number of localities served	13																				
Localities served	Zhalta, Mazraat Aain bou Souar, Jbaa, Kfarfila, Aain Qana, Jernaya, Kfarbeit, Kfarchellal																				
Previously studied by	ASSACO – 2006																				
Design population	2005 Population: 13,797 2030 Population Equivalent: 29,575																				
Daily Average Flow	48.21 l/s																				
Peak flow	150.41 l/s																				
Network																					
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>12.96</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>11.48</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>3.67</td> <td>400</td> </tr> <tr> <td>Pipelines</td> <td>1.56</td> <td>450</td> </tr> <tr> <td>Total Length</td> <td>29.67</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	12.96	200	Pipelines	11.48	300	Pipelines	3.67	400	Pipelines	1.56	450	Total Length	29.67	
Collectors	Length (km)	Diameter (mm)																			
Pipelines	12.96	200																			
Pipelines	11.48	300																			
Pipelines	3.67	400																			
Pipelines	1.56	450																			
Total Length	29.67																				
In-Locality Collection Network	55.11 km																				
Pumping/Lift Station (s)	No pumping stations were proposed by the previous Consultant or by RELK&P at this stage of study.																				
Treatment																					
Design capacity	4,165 m ³ /day																				
WW Characterization	Wastewater characterization was not carried out by the previous Consultant (refer to general notes).																				
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																				
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																				
Additional Remarks	Two small wastewater treatment plants implemented by USAID exist in Jbaa. One is constructed but not yet commissioned while the construction of the second is incomplete. One small operational but ineffective treatment plant also implemented by USAID exists in Kfar Fila.																				

NABATIYEH SCHEME

WW06	South Lebanon Wastewater Master Plan – Nabatiyeh Scheme																																					
Number of localities served	17																																					
Localities served	Kfar Tebnit, Manzieh, El Aqide, Nabatiye El Faouqa, Kfar Roumane, Nabatiyeh Et Tahta, Mazraat Kfar El Jaouz, Habbouche, Zebdine, Harouf, Toul, Kfour, Doueir, Charqiye																																					
Previously studied by	LibanConsult – year NA BTD – 2002 (part of the scheme) Khalil Barakat (part of the scheme)																																					
Design population	2005 Population: 67,893 2030 Population Equivalent: 148,322																																					
Daily Average Flow	292.20 l/s																																					
Peak flow	698.00 l/s																																					
Network																																						
Main Collectors	Collectors proposed by both BTD and Khalil Barakat:																																					
	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>46.15</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>1.96</td> <td>250</td> </tr> <tr> <td>Pipelines</td> <td>4.07</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>0.93</td> <td>350</td> </tr> <tr> <td>Pipelines</td> <td>0.38</td> <td>400</td> </tr> <tr> <td>Pipelines</td> <td>2.01</td> <td>450</td> </tr> <tr> <td>Pipelines</td> <td>1.62</td> <td>500</td> </tr> <tr> <td>Pipelines</td> <td>4.23</td> <td>600</td> </tr> <tr> <td>Pipelines</td> <td>7.10</td> <td>700</td> </tr> <tr> <td>Pipelines</td> <td>15.72</td> <td>800</td> </tr> <tr> <td>Total Length</td> <td>84.17</td> <td></td> </tr> </tbody> </table>		Collectors	Length (km)	Diameter (mm)	Pipelines	46.15	200	Pipelines	1.96	250	Pipelines	4.07	300	Pipelines	0.93	350	Pipelines	0.38	400	Pipelines	2.01	450	Pipelines	1.62	500	Pipelines	4.23	600	Pipelines	7.10	700	Pipelines	15.72	800	Total Length	84.17	
Collectors	Length (km)	Diameter (mm)																																				
Pipelines	46.15	200																																				
Pipelines	1.96	250																																				
Pipelines	4.07	300																																				
Pipelines	0.93	350																																				
Pipelines	0.38	400																																				
Pipelines	2.01	450																																				
Pipelines	1.62	500																																				
Pipelines	4.23	600																																				
Pipelines	7.10	700																																				
Pipelines	15.72	800																																				
Total Length	84.17																																					
In-Locality Collection Network	235 km																																					
Pumping/Lift Station (s)	<table border="1"> <thead> <tr> <th>Items</th> <th>Description</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Pumping/Lift Station at Ouadi Ech Chkhaib</td> <td>1</td> </tr> </tbody> </table>		Items	Description	Quantity	1	Pumping/Lift Station at Ouadi Ech Chkhaib	1																														
Items	Description	Quantity																																				
1	Pumping/Lift Station at Ouadi Ech Chkhaib	1																																				
Treatment																																						
Design capacity	25,246 m ³ /day																																					
WW Characterization	Wastewater characterization was not carried out by the previous Consultants (refer to general notes).																																					
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																																					
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																																					
Additional Remarks																																						

NABAA EL TASSEH SCHEME

WW07	South Lebanon Wastewater Master Plan – Nabaa El Tasseh Scheme																										
Number of localities served	15																										
Localities served	Kfarhoune, Aaramta, Mlikh, El Louaize, Jarjouaa, Arab Salim, Habbouche, Houmine el Faouqa, Mazraat Aaraji																										
Previously studied by	Issal Saleh																										
Design population	2005 Population: 25,068 2030 Population Equivalent: 54,004 p.e. (RELK&P)																										
Daily Average Flow	88.03 l/s																										
Peak flow	249.11 l/s																										
Network																											
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>15.22</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>7.90</td> <td>250</td> </tr> <tr> <td>Pipelines</td> <td>3.78</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>2.00</td> <td>400</td> </tr> <tr> <td>Pipelines</td> <td>11.64</td> <td>500</td> </tr> <tr> <td>Pipelines</td> <td>4.77</td> <td>600</td> </tr> <tr> <td>Total Length</td> <td>45.31</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	15.22	200	Pipelines	7.90	250	Pipelines	3.78	300	Pipelines	2.00	400	Pipelines	11.64	500	Pipelines	4.77	600	Total Length	45.31	
Collectors	Length (km)	Diameter (mm)																									
Pipelines	15.22	200																									
Pipelines	7.90	250																									
Pipelines	3.78	300																									
Pipelines	2.00	400																									
Pipelines	11.64	500																									
Pipelines	4.77	600																									
Total Length	45.31																										
In-Locality Collection Network	97.7km																										
Pumping/Lift Station (s)	No pumping stations were proposed by the previous Consultant or by RELK&P at this stage of study.																										
Treatment																											
Design capacity	7,603 m ³ /day																										
WW Characterization	Wastewater characterization was not carried out by the previous Consultant (refer to general notes).																										
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																										
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																										
Additional Remarks																											

CHAQRA SCHEME

WW08	South Lebanon Wastewater Master Plan – Chaqra Scheme																				
Number of localities served	14																				
Localities served	Maroun Er Ras, Bint Jbeil (10%), Aaitaroun, Beit Yahoun, Kounine, Mhaibib, Meiss El Jabal, Chaqra																				
Previously studied by	Libanconsult – 2005 (only a small part of the village of Chakra)																				
Design population	2005 Population: 33,092 2030 Population Equivalent: 71,335																				
Daily Average Flow	104.58 l/s																				
Peak flow	294.93 l/s																				
Network																					
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>39.89</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>6.57</td> <td>400</td> </tr> <tr> <td>Pipelines</td> <td>4.02</td> <td>500</td> </tr> <tr> <td>Pipelines</td> <td>0.26</td> <td>600</td> </tr> <tr> <td>Total Length</td> <td>50.74</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	39.89	300	Pipelines	6.57	400	Pipelines	4.02	500	Pipelines	0.26	600	Total Length	50.74	
Collectors	Length (km)	Diameter (mm)																			
Pipelines	39.89	300																			
Pipelines	6.57	400																			
Pipelines	4.02	500																			
Pipelines	0.26	600																			
Total Length	50.74																				
In-Locality Collection Network	94.4 km																				
Pumping/Lift Station (s)	<table border="1"> <thead> <tr> <th>Items</th> <th>Description</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Pumping/Lift Station at Chaqra</td> <td>1</td> </tr> </tbody> </table>			Items	Description	Quantity	1	Pumping/Lift Station at Chaqra	1												
Items	Description	Quantity																			
1	Pumping/Lift Station at Chaqra	1																			
Treatment																					
Design capacity	9,035 m ³ /day																				
WW Characterization	Wastewater characterization was not carried out by the previous Consultant (refer to general notes).																				
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																				
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																				
Additional Remarks																					

TIBNINE SCHEME

WW09	South Lebanon Wastewater Master Plan – Tibnine Scheme																						
Number of localities served	7																						
Localities served	Baraachit, Jmajmeh, Sultaniyeh, Safad El Battikh, Haddatha, Aaita Ez Zott, Tibnine																						
Previously studied by	Khalil Barakat Libanconsult – 2005																						
Design population	2005 Population: 16,078 2030 Population Equivalent: 34,206																						
Daily Average Flow	55.76 l/s																						
Peak flow	170.06 l/s																						
Network																							
Main Collectors	Collectors proposed by both Khalil Barakat and Libanconsult:																						
	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>7.97</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>16.62</td> <td>250</td> </tr> <tr> <td>Pipelines</td> <td>11.13</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>2.85</td> <td>350</td> </tr> <tr> <td>Pipelines</td> <td>5.46</td> <td>500</td> </tr> <tr> <td>Total Length</td> <td>44.03</td> <td></td> </tr> </tbody> </table>		Collectors	Length (km)	Diameter (mm)	Pipelines	7.97	200	Pipelines	16.62	250	Pipelines	11.13	300	Pipelines	2.85	350	Pipelines	5.46	500	Total Length	44.03	
Collectors	Length (km)	Diameter (mm)																					
Pipelines	7.97	200																					
Pipelines	16.62	250																					
Pipelines	11.13	300																					
Pipelines	2.85	350																					
Pipelines	5.46	500																					
Total Length	44.03																						
In-Locality Collection Network	73 km																						
Pumping/Lift Station (s)	<table border="1"> <thead> <tr> <th>Items</th> <th>Description</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Pumping station at Braachit</td> <td>1</td> </tr> <tr> <td>2</td> <td>Pumping station at Jmajme</td> <td>1</td> </tr> </tbody> </table>		Items	Description	Quantity	1	Pumping station at Braachit	1	2	Pumping station at Jmajme	1												
Items	Description	Quantity																					
1	Pumping station at Braachit	1																					
2	Pumping station at Jmajme	1																					
Treatment																							
Design capacity	4,817 m3/day																						
WW Characterization	Wastewater characterization was not carried out by the previous Consultants (refer to general notes).																						
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																						
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																						
Additional Remarks	RELK&P adopted and combined the proposals by both Khalil Barakat and Libanconsult in it's Master Plan																						

BINT JBEIL SCHEME

WW10	South Lebanon Wastewater Master Plan – Bint Jbeil Scheme																									
Number of localities served	17																									
Localities served	Aain Ebel, Hanine, Yaroun, Bint Jbeil, Rmaich, Debel, Aaita Ech Chaab, Tiri, Rchaf, Srobbine, Yater, Beit Lif, Qouzah, Ramiye																									
Previously studied by	Liban Consult – 2005 (this study by Liban Consult covered only certain parts of the Bint Jbeil scheme proposed by RELK&P)																									
Design population	2005 Population: 36,157 2030 Population Equivalent: 77,389																									
Daily Average Flow	126.14 l/s																									
Peak flow	335.54 l/s																									
Network																										
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>35.17</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>4.48</td> <td>350</td> </tr> <tr> <td>Pipelines</td> <td>2.64</td> <td>400</td> </tr> <tr> <td>Pipelines</td> <td>1.00</td> <td>500</td> </tr> <tr> <td>Pipelines</td> <td>4.23</td> <td>600</td> </tr> <tr> <td>Pipelines</td> <td>5.57</td> <td>700</td> </tr> <tr> <td>Total Length</td> <td>53.09</td> <td></td> </tr> </tbody> </table>		Collectors	Length (km)	Diameter (mm)	Pipelines	35.17	300	Pipelines	4.48	350	Pipelines	2.64	400	Pipelines	1.00	500	Pipelines	4.23	600	Pipelines	5.57	700	Total Length	53.09	
Collectors	Length (km)	Diameter (mm)																								
Pipelines	35.17	300																								
Pipelines	4.48	350																								
Pipelines	2.64	400																								
Pipelines	1.00	500																								
Pipelines	4.23	600																								
Pipelines	5.57	700																								
Total Length	53.09																									
In-Locality Collection Network	144 km																									
Pumping/Lift Station (s)	No pumping stations were proposed by the previous Consultant or by RELK&P at this stage of study.																									
Treatment																										
Design capacity	10,898 m3/day																									
WW Characterization	Wastewater characterization was not carried out by the previous Consultant (refer to general notes).																									
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																									
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																									
Additional Remarks																										

MARJAAYOUN SCHEME

WW11	South Lebanon Wastewater Master Plan – Marjaayoun Scheme																										
Number of localities served	10																										
Localities served	Blat, Dibbine, Marjaayoun, Ebel es Saqi, El Khiam, El Qlaiaa, Bourj el Moulouk																										
Previously studied by	BTD - 2004																										
Design population	2005 Population: 26,564 2030 Population Equivalent: 58,053																										
Daily Average Flow	94.63 l/s																										
Peak flow	264.01 l/s																										
Network																											
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>10.40</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>19.15</td> <td>250</td> </tr> <tr> <td>Pipelines</td> <td>20.82</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>5.32</td> <td>400</td> </tr> <tr> <td>Pipelines</td> <td>10.30</td> <td>500</td> </tr> <tr> <td>Pipelines</td> <td>0.57</td> <td>600</td> </tr> <tr> <td>Total Length</td> <td>66.56</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	10.40	200	Pipelines	19.15	250	Pipelines	20.82	300	Pipelines	5.32	400	Pipelines	10.30	500	Pipelines	0.57	600	Total Length	66.56	
Collectors	Length (km)	Diameter (mm)																									
Pipelines	10.40	200																									
Pipelines	19.15	250																									
Pipelines	20.82	300																									
Pipelines	5.32	400																									
Pipelines	10.30	500																									
Pipelines	0.57	600																									
Total Length	66.56																										
In-Locality Collection Network	102.4 km																										
Pumping/Lift Station (s)	<table border="1"> <thead> <tr> <th>Items</th> <th>Description</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Pumping/Lift Station at Dibbine</td> <td>1</td> </tr> <tr> <td>2</td> <td>Pumping/Lift Station at El Khiam</td> <td>1</td> </tr> <tr> <td>3</td> <td>Pumping/Lift Station at Ebel es Saqi</td> <td>1</td> </tr> <tr> <td>4</td> <td>Pumping/Lift Stations at Qlaiaa</td> <td>2</td> </tr> <tr> <td>5</td> <td>Pumping/Lift Station west of Marj el Khiam</td> <td>1</td> </tr> </tbody> </table>			Items	Description	Quantity	1	Pumping/Lift Station at Dibbine	1	2	Pumping/Lift Station at El Khiam	1	3	Pumping/Lift Station at Ebel es Saqi	1	4	Pumping/Lift Stations at Qlaiaa	2	5	Pumping/Lift Station west of Marj el Khiam	1						
Items	Description	Quantity																									
1	Pumping/Lift Station at Dibbine	1																									
2	Pumping/Lift Station at El Khiam	1																									
3	Pumping/Lift Station at Ebel es Saqi	1																									
4	Pumping/Lift Stations at Qlaiaa	2																									
5	Pumping/Lift Station west of Marj el Khiam	1																									
Treatment																											
Design capacity	8,176 m ³ /day																										
WW Characterization	Wastewater characterization was not carried out by the previous Consultant (refer to general notes).																										
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																										
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout (in the Khiam plain)																										
Additional Remarks	Small rural wastewater treatment plants implemented by USAID exist in El Khiam and Bourj El Moulouk. At Khiam the plant is operational but not functioning properly. At Bourj el Moulouk there are two plants which have been constructed but not yet commissioned.																										

JEZZINE SCHEME

WW12	South Lebanon Wastewater Master Plan – Jezzine Scheme																	
Number of localities served	24																	
Localities served	Aain Majdalaine, Jezzine, Ouadi Jezzine, Sabbah, Bkassine, Aaray, Bhannine, Deir Machmouche, Machmouche, Bteddine El Liqch, El Harf, El Midane, Benouati, El Ghbatiye																	
Previously studied by	No previous studies were conducted.																	
Design population	2005 Population: 11,736 2030 Population Equivalent: 24,906																	
Daily Average Flow	40.60 l/s																	
Peak flow	130.31 l/s																	
Network																		
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>22.55</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>1.86</td> <td>350</td> </tr> <tr> <td>Pipelines</td> <td>2.03</td> <td>400</td> </tr> <tr> <td>Total Length</td> <td>26.44</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	22.55	300	Pipelines	1.86	350	Pipelines	2.03	400	Total Length	26.44	
Collectors	Length (km)	Diameter (mm)																
Pipelines	22.55	300																
Pipelines	1.86	350																
Pipelines	2.03	400																
Total Length	26.44																	
In-Locality Collection Network	45.7 km																	
Pumping/Lift Station (s)	<table border="1"> <thead> <tr> <th>Items</th> <th>Description</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Pumping/Lift Station at Midane</td> <td>1</td> </tr> </tbody> </table>			Items	Description	Quantity	1	Pumping/Lift Station at Midane	1									
Items	Description	Quantity																
1	Pumping/Lift Station at Midane	1																
Treatment																		
Design capacity	3,508 m ³ /day																	
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).																	
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																	
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																	
Additional Remarks	There is one USAID funded treatment plant located in Ouadi Jezzine and one in El Ghbatiye. The plant in Ouadi Jezzine is operating properly whereas the one in El Ghbatiye has been constructed but not yet commissioned.																	

MAIFADOUN/BRAIQAA SCHEME

WW13	South Lebanon Wastewater Master Plan – Maifadoun / Braiqaa scheme																						
Number of localities served	11																						
Localities served	Maifadoun, Choukine, Qaaqaiyet El Jisr, Jaouhariye, Aadchit, Qsaibe, Braiqaaa, Harouf (50%), Jibchit, Aabba																						
Previously studied by	No previous studies were conducted.																						
Design population	2005 Population: 30,466 2030 Population Equivalent: 64,815																						
Daily Average Flow	105.65 l/s																						
Peak flow	289.48 l/s																						
Network																							
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>13.54</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>2.46</td> <td>350</td> </tr> <tr> <td>Pipelines</td> <td>11.36</td> <td>400</td> </tr> <tr> <td>Pipelines</td> <td>3.69</td> <td>500</td> </tr> <tr> <td>Pipelines</td> <td>1.17</td> <td>600</td> </tr> <tr> <td>Total Length</td> <td>32.22</td> <td></td> </tr> </tbody> </table>		Collectors	Length (km)	Diameter (mm)	Pipelines	13.54	300	Pipelines	2.46	350	Pipelines	11.36	400	Pipelines	3.69	500	Pipelines	1.17	600	Total Length	32.22	
Collectors	Length (km)	Diameter (mm)																					
Pipelines	13.54	300																					
Pipelines	2.46	350																					
Pipelines	11.36	400																					
Pipelines	3.69	500																					
Pipelines	1.17	600																					
Total Length	32.22																						
In-Locality Collection Network	122.7 km																						
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.																						
Treatment																							
Design capacity	9,128 m ³ /day																						
WW Characterization	Wastewater characterization was not carried out by at this stage of study (refer to general notes).																						
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																						
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																						
Additional Remarks																							

KFAR SIR SCHEME

WW14	South Lebanon Wastewater Master Plan - Kfar Sir Scheme 2 sub-schemes																																	
Number of localities served	2																																	
Localities served	Sir el Gharbiyeh and Kfar Sir																																	
Previously studied by	Issal Saleh –Year NA																																	
Design population	<i>Sub-scheme 1:</i> 2005 Population: 3,276 2030 Population Equivalent: 6,970 <i>Sub-scheme 2:</i> 2005 Population: 9,360 2030 Population Equivalent: 20,405																																	
Daily Average Flow	Sub-scheme 1: 11 l/s Sub-scheme 2: 33 l/s																																	
Peak flow	Sub-scheme 1: 45 l/s Sub-scheme 2: 110 l/s																																	
Network																																		
Main Collectors	<p>Sub-scheme 1:</p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>1.95</td> <td>200</td> </tr> <tr> <td>Total length</td> <td>1.95</td> <td></td> </tr> </tbody> </table> <p>Sub-scheme 2:</p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>3.88</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>0.06</td> <td>300</td> </tr> <tr> <td>Total length</td> <td>3.94</td> <td></td> </tr> </tbody> </table> <p>Total length of collectors:</p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>5.84</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>0.06</td> <td>300</td> </tr> <tr> <td>Grand total length</td> <td>5.90</td> <td></td> </tr> </tbody> </table>	Collectors	Length (km)	Diameter (mm)	Pipelines	1.95	200	Total length	1.95		Collectors	Length (km)	Diameter (mm)	Pipelines	3.88	200	Pipelines	0.06	300	Total length	3.94		Collectors	Length (km)	Diameter (mm)	Pipelines	5.84	200	Pipelines	0.06	300	Grand total length	5.90	
Collectors	Length (km)	Diameter (mm)																																
Pipelines	1.95	200																																
Total length	1.95																																	
Collectors	Length (km)	Diameter (mm)																																
Pipelines	3.88	200																																
Pipelines	0.06	300																																
Total length	3.94																																	
Collectors	Length (km)	Diameter (mm)																																
Pipelines	5.84	200																																
Pipelines	0.06	300																																
Grand total length	5.90																																	
In-Locality Collection Network	<i>Sub-scheme 1: 13 km</i> <i>Sub-scheme 2: 32.8 km</i>																																	
Pumping/Lift Station (s)	No pumping stations were proposed by the previous Consultants or by RELK&P at this stage of study.																																	
Treatment																																		
Design Capacity	<i>Sub-scheme 1: 950 m³/day</i> <i>Sub-scheme 2: 2,851 m³/day</i>																																	
WW Characterization	Wastewater characterization was not carried out by the previous Consultant (refer to general notes).																																	
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																																	
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																																	
Additional Remarks																																		

HALLOUSIEH SCHEME

WW15	South Lebanon Wastewater Master Plan – Hallousieh scheme													
Number of localities served	4													
Localities served	Hmairi, Tair Filsay, and HalloussiyeH													
Previously studied by	Issal Saleh													
Design population	2005 Population: 6,110 2030 Population Equivalent: 12,924													
Daily Average Flow	21.07 l/s													
Peak flow	75.63 l/s													
Network														
Main Collectors	<table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>6.22</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>0.15</td> <td>250</td> </tr> <tr> <td>Total Length</td> <td>6.37</td> <td></td> </tr> </tbody> </table>		Collectors	Length (km)	Diameter (mm)	Pipelines	6.22	200	Pipelines	0.15	250	Total Length	6.37	
Collectors	Length (km)	Diameter (mm)												
Pipelines	6.22	200												
Pipelines	0.15	250												
Total Length	6.37													
In-Locality Collection Network	27.2 km													
Pumping/Lift Station (s)	No pumping stations were proposed by the previous Consultant or by RELK&P at this stage of study.													
Treatment														
Design Capacity	1,820 m ³ /day													
WW Characterization	Wastewater characterization was not carried out by the previous Consultant (refer to general notes).													
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge													
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout													
Additional Remarks														

SRIFA SCHEME

WW16	South Lebanon Wastewater Master Plan – Srifa scheme														
Number of localities served	6														
Localities served	Niha, Qalaat Maroun, Deir Kifa, Srifa, Baqliye														
Previously studied by	No studies were previously conducted.														
Design population	2005 Population: 10,868 2030 Population Equivalent: 23,491														
Daily Average Flow	38.29 l/s														
Peak flow	124.44 l/s														
Network															
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>8.62</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>0.25</td> <td>400</td> </tr> <tr> <td>Total Length</td> <td>8.87</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	8.62	300	Pipelines	0.25	400	Total Length	8.87	
Collectors	Length (km)	Diameter (mm)													
Pipelines	8.62	300													
Pipelines	0.25	400													
Total Length	8.87														
In-Locality Collection Network	44 km														
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.														
Treatment															
Design Capacity	3,308 m ³ /day														
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).														
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge														
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout														
Additional Remarks															

WADI SLOUQI SCHEME

WW17	South Lebanon Wastewater Master Plan – Wadi Slouqi Scheme																									
Number of localities served	19																									
Localities served	Majdel Selm, Jmaijme, Khirbet Selm, Markaba, Aadaiseh, Taibeh, Souane, Tallousa, Aadshit el Qsair, Qantara, Touline, Bourj Qalaouiyeh, Ghandouriyeh, El Qsair, Froun, Houla, Qalaouay, Bani Hayane, Qabrikha																									
Previously studied by	No studies were previously conducted.																									
Design population	2005 Population: 41,970 2030 Population Equivalent: 89,814																									
Daily Average Flow	176.93 l/s																									
Peak flow	406.95 l/s																									
Network																										
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>65.24</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>3.89</td> <td>400</td> </tr> <tr> <td>Pipelines</td> <td>3.99</td> <td>450</td> </tr> <tr> <td>Pipelines</td> <td>4.16</td> <td>500</td> </tr> <tr> <td>Pipelines</td> <td>2.73</td> <td>600</td> </tr> <tr> <td>Pipelines</td> <td>0.48</td> <td>700</td> </tr> <tr> <td>Total Length</td> <td>80.49</td> <td></td> </tr> </tbody> </table>		Collectors	Length (km)	Diameter (mm)	Pipelines	65.24	300	Pipelines	3.89	400	Pipelines	3.99	450	Pipelines	4.16	500	Pipelines	2.73	600	Pipelines	0.48	700	Total Length	80.49	
Collectors	Length (km)	Diameter (mm)																								
Pipelines	65.24	300																								
Pipelines	3.89	400																								
Pipelines	3.99	450																								
Pipelines	4.16	500																								
Pipelines	2.73	600																								
Pipelines	0.48	700																								
Total Length	80.49																									
In-Locality Collection Network	176 km																									
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.																									
Treatment																										
Design capacity	15,293 m3/day																									
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).																									
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																									
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																									
Additional Remarks																										

YOHMOR SCHEME

WW18	South Lebanon Wastewater Master Plan – Yohmor Scheme											
Number of localities served	1											
Localities served	Yohmor village											
Previously studied by	No studies were previously conducted.											
Design population	2005 Population: 2,340 2030 Population Equivalent: 4,978											
Daily Average Flow	8.11 l/s											
Peak flow	34.08 l/s											
Network												
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>2.34</td> <td>300</td> </tr> <tr> <td>Total Length</td> <td>2.34</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	2.34	300	Total Length	2.34	
Collectors	Length (km)	Diameter (mm)										
Pipelines	2.34	300										
Total Length	2.34											
In-Locality Collection Network	9.4 km											
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.											
Treatment												
Design capacity	701 m3/day											
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks												

ZAOUTAR SCHEME

WW19	South Lebanon Wastewater Master Plan – Zaoutar Scheme											
Number of localities served	2											
Localities served	Zaoutar Charquiye & Zaoutar Gharbiyeh											
Previously studied by	No studies were previously conducted.											
Design population	2005 Population: 1,189 2030 Population Equivalent: 2,529											
Daily Average Flow	4.12 l/s											
Peak flow	22.67 l/s											
Network												
Main Collectors	<table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>1.91</td> <td>200</td> </tr> <tr> <td>Total Length</td> <td>1.91</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	1.91	200	Total Length	1.91	
Collectors	Length (km)	Diameter (mm)										
Pipelines	1.91	200										
Total Length	1.91											
In-Locality Collection Network	5.9 km											
Pumping/Lift Station (s)	<table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Description</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>Pumping station at Zaoutar Ech Charquiye</td> <td>1</td> </tr> </tbody> </table>			Description	Quantity	Pumping station at Zaoutar Ech Charquiye	1					
Description	Quantity											
Pumping station at Zaoutar Ech Charquiye	1											
Treatment												
Design capacity	356 m3/day											
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks												

DEIR MIMMES SCHEME

WW20	South Lebanon Wastewater Master Plan – Deir Mimmes Scheme																	
Number of localities served	3																	
Localities served	Kfarkila, Houla, and Deir Mimes																	
Previously studied by	No studies were previously conducted.																	
Design population	2005 Population: 6,525 2030 Population Equivalent: 13,882																	
Daily Average Flow	22.63 l/s																	
Peak flow	80.10 l/s																	
Network																		
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>3.85</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>2.69</td> <td>300</td> </tr> <tr> <td>Pipelines</td> <td>0.35</td> <td>400</td> </tr> <tr> <td>Total Length</td> <td>6.89</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	3.85	200	Pipelines	2.69	300	Pipelines	0.35	400	Total Length	6.89	
Collectors	Length (km)	Diameter (mm)																
Pipelines	3.85	200																
Pipelines	2.69	300																
Pipelines	0.35	400																
Total Length	6.89																	
In-Locality Collection Network	27.7 km																	
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.																	
Treatment																		
Design capacity	1,955 m ³ /day																	
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).																	
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																	
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																	
Additional Remarks	A small rural operational wastewater treatment plant implemented by USAID exists in Deir Mimes.																	

EL AACHIYEH SCHEME

WW21	South Lebanon Wastewater Master Plan – El Aachiyeh Scheme											
Number of localities served	3											
Localities served	El Aaichiye & Nabaa and Dellafa which are the suburbs of El Aachiyeh village											
Previously studied by	No studies were previously conducted.											
Design population	2005 Population: 814 2030 Population Equivalent: 1,670											
Daily Average Flow	2.72 l/s											
Peak flow	14.97 l/s											
Network												
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>2.15</td> <td>200</td> </tr> <tr> <td>Total Length</td> <td>2.15</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	2.15	200	Total Length	2.15	
Collectors	Length (km)	Diameter (mm)										
Pipelines	2.15	200										
Total Length	2.15											
In-Locality Collection Network	4.1 km											
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.											
Treatment												
Design capacity	235 m3/day											
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks	A wastewater treatment plant implemented by USAID exists in El Aachiyeh and it is operating properly. This area is served by the existing USAID treatment plant up until the year 2015. The Consultant team, after investigating the treatment plant site, recommended expansion of this treatment plant site to provide service up until the year 2030.											

KAFRA SCHEME

WW22	South Lebanon Wastewater Master Plan – Kafra Scheme																	
Number of localities served	2																	
Localities served	Kafra and Haris																	
Previously studied by	No studies were previously conducted.																	
Design population	2005 Population: 7,668 2030 Population Equivalent: 16,314																	
Daily Average Flow	26.59 l/s																	
Peak flow	91.74 l/s																	
Network																		
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>2.52</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>1.74</td> <td>250</td> </tr> <tr> <td>Pipelines</td> <td>0.26</td> <td>300</td> </tr> <tr> <td>Total Length</td> <td>4.52</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	2.52	200	Pipelines	1.74	250	Pipelines	0.26	300	Total Length	4.52	
Collectors	Length (km)	Diameter (mm)																
Pipelines	2.52	200																
Pipelines	1.74	250																
Pipelines	0.26	300																
Total Length	4.52																	
In-Locality Collection Network	31 km																	
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.																	
Treatment																		
Design capacity	2,297 m ³ /day																	
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).																	
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge																	
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout																	
Additional Remarks																		

RIHANE SCHEME

WW23	South Lebanon Wastewater Master Plan – Rihane Scheme														
Number of localities served	3														
Localities served	Soujoud and Rihane														
Previously studied by	No studies were previously conducted.														
Design population	2005 Population: 3,328 2030 Population Equivalent: 7,081														
Daily Average Flow	11.54 l/s														
Peak flow	45.82 l/s														
Network															
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>4.15</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>0.23</td> <td>250</td> </tr> <tr> <td>Total Length</td> <td>4.38</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	4.15	200	Pipelines	0.23	250	Total Length	4.38	
Collectors	Length (km)	Diameter (mm)													
Pipelines	4.15	200													
Pipelines	0.23	250													
Total Length	4.38														
In-Locality Collection Network	14.5 km														
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.														
Treatment															
Design capacity	997 m ³ /day														
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).														
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge														
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout														
Additional Remarks	A small rural wastewater treatment plant has been implemented by USAID in Rihane. This treatment plant has been rehabilitated to adopt extended aeration technology. However said plant has not yet been connected to the network.														

MIMESS SCHEME

WW24	South Lebanon Wastewater Master Plan – Mimesse Scheme														
Number of localities served	5														
Localities served	Kfair, Khalouat El Kfair, Mimesse, Bathaniyeh														
Previously studied by	Camp Dresser and McKee (CDM) 1982														
Design population	2005 Population: 4,120 2030 Population Equivalent: 8,765														
Daily Average Flow	14.29 l/s														
Peak flow	50.43 l/s														
Network															
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>12.33</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>5.15</td> <td>300</td> </tr> <tr> <td>Total Length</td> <td>17.48</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	12.33	200	Pipelines	5.15	300	Total Length	17.48	
Collectors	Length (km)	Diameter (mm)													
Pipelines	12.33	200													
Pipelines	5.15	300													
Total Length	17.48														
In-Locality Collection Network	20.60 km														
Pumping/Lift Station (s)	No pumping stations were proposed by the previous Consultant or RELK&P at this stage of study														
Treatment															
Design capacity	1,235 m ³ /day														
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).														
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge														
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout														
Additional Remarks	Two wastewater treatment plants implemented by USAID exist in Mimesse and one also implemented by USAID exists in Kfair. In Mimesse both plants are ready for operation but have not yet been commissioned. In Kfair the plant is ready for operation but has not yet been commissioned.														

HASBAYA SCHEME

WW25	South Lebanon Wastewater Master Plan – Hasbaya Scheme																			
Number of localities served	5																			
Localities served	Hasbaya, Mazraat Ras El Baidar, Chouaya, Zaghla, Ain Qenia																			
Previously studied by	Rafik El-Khoury & Partners – 2006																			
Design population	2005 Population: 10,290 2030 Population Equivalent: 22,333																			
Daily Average Flow	42.63 l/s																			
Peak flow	139.40 l/s																			
Network																				
Main Collectors	<p>Hasbaya project sewer network details:</p> <table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines in roads</td> <td>13.60</td> <td>300</td> </tr> <tr> <td>Pipelines in roads</td> <td>3.95</td> <td>400</td> </tr> <tr> <td>Pipelines in roads</td> <td>1.40</td> <td>500</td> </tr> <tr> <td>Pipelines in natural grounds – river course</td> <td>2.10</td> <td>400</td> </tr> <tr> <td>TOTAL LENGTH</td> <td>21.05</td> <td></td> </tr> </tbody> </table>		Collectors	Length (km)	Diameter (mm)	Pipelines in roads	13.60	300	Pipelines in roads	3.95	400	Pipelines in roads	1.40	500	Pipelines in natural grounds – river course	2.10	400	TOTAL LENGTH	21.05	
Collectors	Length (km)	Diameter (mm)																		
Pipelines in roads	13.60	300																		
Pipelines in roads	3.95	400																		
Pipelines in roads	1.40	500																		
Pipelines in natural grounds – river course	2.10	400																		
TOTAL LENGTH	21.05																			
In-Locality Collection Network	38.85 km																			
Pumping/Lift Station (s)	<p>A small-sized pumping station has been proposed for pumping the sewage resulting from the southeastern part of Chouwaya village</p> <table border="1"> <thead> <tr> <th>Items</th> <th>Description</th> <th>Quantity</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Pumping station at Chouwaya</td> <td>1</td> </tr> </tbody> </table>		Items	Description	Quantity	1	Pumping station at Chouwaya	1												
Items	Description	Quantity																		
1	Pumping station at Chouwaya	1																		
Treatment																				
Design capacity	3,683 m ³ /day																			
WW Characterization	<p>Grab water samples were taken at points where municipal WW is mixed with WW resulting from local olive oil mills from villages in the Caza of Hasbaya. The WW was found to have the following characteristics:</p> <p>BOD₅ 825 mg/l TSS 750 mg/l</p>																			
Proposed WW treatment process	<p>Secondary biological treatment through suspended growth process (Extended Aeration Activated Sludge) with chlorine disinfection. Sludge treatment: sludge dewatering</p>																			
Proposed location of WWTP	<p>The WWTP is proposed to be built on the left bank of the Hasbani River on a privately owned parcel. Plot Numbers: 4307, 4308, 4309 with a total surface area equal to 12,310m² (refer to map).</p>																			
Additional Remarks	<p>Small rural wastewater treatment plants have been implemented by USAID in Hasbaya, Ain Qenia and Chouaya. There are two plants in Hasbaya, one of which has been rehabilitated and upgraded to extended aeration while construction of the second plant has been completed. There are three plants in Ain Qenia which are operational. In Chouaya a new plant has recently been constructed.</p>																			

HEBBARIYEH SCHEME

WW26	South Lebanon Wastewater Master Plan – Hebbariyeh Scheme														
Number of localities served	4														
Localities served	Ain Jerfa, Khalouat el Baiyada, Hebbariye, Fardis														
Previously studied by	No studies were previously conducted														
Design population	2005 Population: 3,793 2030 Population Equivalent: 8,007														
Daily Average Flow	13.05 l/s														
Peak flow	50.63 l/s														
Network															
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>5.92</td> <td>200</td> </tr> <tr> <td>Pipelines</td> <td>0.36</td> <td>300</td> </tr> <tr> <td>Total Length</td> <td>6.28</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	5.92	200	Pipelines	0.36	300	Total Length	6.28	
Collectors	Length (km)	Diameter (mm)													
Pipelines	5.92	200													
Pipelines	0.36	300													
Total Length	6.28														
In-Locality Collection Network	18.97 km														
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.														
Treatment															
Design capacity	1,127 m ³ /day														
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).														
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge														
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout														
Additional Remarks	Small rural wastewater treatment plants implemented by USAID exist in Hebbariyeh, Ain Jerfa and Fardis. At Ain Jerfa there is one treatment plant which is operational. At Hebbariyeh a new plant has recently been constructed. At Fardis a new plant has also recently been constructed.														

KAOUKABA SCHEME

WW27	South Lebanon Wastewater Master Plan – Kaoukaba Scheme											
Number of localities served	1											
Localities served	Kaoukaba village											
Previously studied by	No studies were previously conducted											
Design population	2005 Population: 953 2030 Population Equivalent: 1955											
Daily Average Flow	3.19 l/s											
Peak flow	15.68 l/s											
Network												
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>1.59</td> <td>200</td> </tr> <tr> <td>Total Length</td> <td>1.59</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	1.59	200	Total Length	1.59	
Collectors	Length (km)	Diameter (mm)										
Pipelines	1.59	200										
Total Length	1.59											
In-Locality Collection Network	4.77 km											
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.											
Treatment												
Design capacity	276 m ³ /day											
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks	A small new rural wastewater treatment plant implemented by USAID has recently been constructed in Kaoukaba.											

RACHAYA EL FOUKHAR SCHEME

WW28	South Lebanon Wastewater Master Plan – Rachaya El Foukhar Scheme											
Number of localities served	2											
Localities served	Rachaya el Foukhar, Kfar Hamam											
Previously studied by	No studies were previously conducted											
Design population	2005 Population: 1,827 2030 Population Equivalent: 3,748											
Daily Average Flow	6.11 l/s											
Peak flow	27.01 l/s											
Network												
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>4.73</td> <td>200</td> </tr> <tr> <td>Total Length</td> <td>4.73</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	4.73	200	Total Length	4.73	
Collectors	Length (km)	Diameter (mm)										
Pipelines	4.73	200										
Total Length	4.73											
In-Locality Collection Network	9.14 km											
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.											
Treatment												
Design capacity	528 m3/day											
WW Characterization	Wastewater characterization was not carried out at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks	A small rural wastewater treatment plant implemented by USAID has recently been constructed in Kfar Hamam											

KFARCHOUBA SCHEME

WW29	South Lebanon Wastewater Master Plan – Kfarchouba Scheme											
Number of localities served	1											
Localities served	Kfarchouba village											
Previously studied by	No studies were previously conducted											
Design population	2005 Population: 2,604 2030 Population Equivalent: 5,540											
Daily Average Flow	9.03 l/s											
Peak flow	37.29 l/s											
Network												
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>2.03</td> <td>200</td> </tr> <tr> <td>Total Length</td> <td>2.03</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	2.03	200	Total Length	2.03	
Collectors	Length (km)	Diameter (mm)										
Pipelines	2.03	200										
Total Length	2.03											
In-Locality Collection Network	10.42 km											
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.											
Treatment												
Design capacity	781 m3/day											
WW Characterization	Wastewater characterization was not carried out by at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks												

EL MERI SCHEME

WW30	South Lebanon Wastewater Master Plan – El Mari Scheme											
Number of localities served	1											
Localities served	El Mari village											
Previously studied by	No studies were previously conducted											
Design population	2005 Population: 1,067 2030 Population Equivalent: 2,270											
Daily Average Flow	3.70 l/s											
Peak flow	17.76 l/s											
Network												
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>0.97</td> <td>200</td> </tr> <tr> <td>Total Length</td> <td>0.97</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	0.97	200	Total Length	0.97	
Collectors	Length (km)	Diameter (mm)										
Pipelines	0.97	200										
Total Length	0.97											
In-Locality Collection Network	5.34 km											
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.											
Treatment												
Design capacity	320 m3/day											
WW Characterization	Wastewater characterization was not carried out by at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks	A small rural wastewater treatment plant implemented by USAID has recently been constructed in El Meri.											

EL WAZZANI SCHEME

WW31	South Lebanon Wastewater Master Plan – El Wazzani Scheme											
Number of localities served	1											
Localities served	El Wazzani village											
Previously studied by	No studies were previously conducted											
Design population	2005 Population: 194 2030 Population Equivalent: 397											
Daily Average Flow	1 l/s											
Peak flow	4 l/s											
Network												
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>0.45</td> <td>200</td> </tr> <tr> <td>Total Length</td> <td>0.45</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	0.45	200	Total Length	0.45	
Collectors	Length (km)	Diameter (mm)										
Pipelines	0.45	200										
Total Length	0.45											
In-Locality Collection Network	0.37 km											
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.											
Treatment												
Design capacity	86.4 m ³ /day											
WW Characterization	Wastewater characterization was not carried out by at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks	A small rural wastewater treatment plant has been implemented by USAID in El Wazzani and this plant is operational.											

CHEBAA SCHEME

WW32	South Lebanon Wastewater Master Plan – Chebaa Scheme											
Number of localities served	1											
Localities served	Chebaa village											
Previously studied by	No studies were previously conducted											
Design population	2005 Population: 10,080 2030 Population Equivalent: 22,516											
Daily Average Flow	44.36 l/s											
Peak flow	145.49 l/s											
Network												
Main Collectors	<table border="1"> <thead> <tr> <th>Collectors</th> <th>Length (km)</th> <th>Diameter (mm)</th> </tr> </thead> <tbody> <tr> <td>Pipelines</td> <td>2.47</td> <td>400</td> </tr> <tr> <td>Total Length</td> <td>2.47</td> <td></td> </tr> </tbody> </table>			Collectors	Length (km)	Diameter (mm)	Pipelines	2.47	400	Total Length	2.47	
Collectors	Length (km)	Diameter (mm)										
Pipelines	2.47	400										
Total Length	2.47											
In-Locality Collection Network	35.28 km											
Pumping/Lift Station (s)	No pumping stations were proposed by RELK&P at this stage of study.											
Treatment												
Design capacity	3,833 m ³ /day											
WW Characterization	Wastewater characterization was not carried out by at this stage of study (refer to general notes).											
Proposed WW treatment process	Aerobic: Extended Aeration Activated Sludge											
Proposed location of WWTP	Proposed as approximately indicated in the Master Plan layout											
Additional Remarks	One wastewater treatment plant implemented by USAID exists in Chebaa and construction of said plant has been completed. The Municipality needs to separate the storm water from the sewer network.											